## THE PUBLIC SERVICE COMMISSION OF SOUTH CAROLINA

#### **DOCKET NO. 2018-257-WS**

IN RI	E: Application of Kiawah Island Utility, Inc. for Adjustment of Rates and Charges and Modifications to Certain Terms and Conditions for the Provision of Water and Sewer Service  REBUTTAL TESTIMONY  OF  BECKY DENNIS
Q.	PLEASE STATE YOUR NAME.
A.	My name is Becky Dennis. My business address is 31 Sora Rail Road, Kiawah Island,
	South Carolina.
Q.	DID YOU ALSO SPONSOR DIRECT TESTIMONY IN THIS CASE?
A.	Yes, my direct testimony was filed on January 31, 2019.
Q.	WHAT IS THE PURPOSE OF YOUR TESTIMONY?
A.	The purpose of this testimony is to respond to the assertions regarding fire hydrant fees
	described in the rebuttal testimony of St. John's Fire District's ("SJFD") witnesses
	Chief Colleen Walz, Commissioner Debra Lehman, Commissioner William Thomae,
	and Assistant Chief Gavin Gilcrease (collectively, "SJFD witnesses").
Q.	PLEASE SUMMARIZE THE TESTIMONY OF THE SJFD WITNESSES.
A.	The SJFD witnesses questioned KIU's supporting calculation for the amount of the
	hydrant fee, disputed the validity of the fee, recommended that the costs of maintaining
	fire hydrants should be recovered in base rates rather than through a hydrant fees, and
	asserted that charging the hydrant fee results in Wadmalaw residents subsidizing KIU's
	customers. KIII will respond to each of these points in turn

## Q. PLEASE SUMMARIZE AND RESPOND TO THE SJFD WITNESSES'S ASSERTION THAT THE HYDRANT FEE IS NOT VALID.

A.

Commissioner Lehman asserts that "there is no rational relationship between the amount charged and the services rendered" due to five factors, including the expiration of an alleged 20 year time period for the fee, the reimbursement of costs by developers, the increase in number of hydrants, the incorporation of Kiawah as a town, and water supplied by a regulated investor-owned utility. None of the five factors cited by Commissioner Lehman deny KIU's cost justification for the hydrant fee.

Commissioner Lehman alleges "Although no signed contracts can be found, it appears from meeting minutes in 1979 that the original intent was for the flat fee 'rent' to extend for a period of 20 years." KIU believes the meeting minutes referred to actually reference an agreement between SJFD and St. Johns Water Company which was never signed and to which KIU was never a party. Without an executed contract and with questions over whether those 1979 meeting minutes even relate to the hydrant fees charged by KIU, KIU cannot accept that the fee was originally intended to be charged for only a 20-year period.

Commissioner Lehman is correct that there has been an increase in fire hydrants on Kiawah Island. On Kiawah Island, all hydrants are within 500 feet of each other, allowing for the fire department to provide better coverage to the residents of Kiawah Island. The growth in hydrants mirrors that of development; once development growth slowed, so did the trend in fire hydrant additions. In fact, from 2015 to 2018 there were

only four hydrants added to the system. Commissioner Lehman does not explain why an increase in the number of hydrants should lower the cost to maintain them.

Commissioner Lehman states "Kiawah has developed into an upscale community and is now incorporated as a town." She points out that Kiawah's water supply is provided by a regulated investor-owned utility. Again there is no explanation of why these facts justify eliminating the hydrant fee. The incorporation of the town, the affluence of its residents, and the nature of the town's water supplier has no bearing on the need to maintain hydrants.

Commissioner Lehman asserts that "infrastructure costs are now reimbursed by developers." Over the course of development, all hydrants located on the transmission system were purchased by KIU from the developers, and all hydrants located on distribution lines were donated to KIU. But SJFD is not being charged for the hydrants themselves. Regardless of how they were acquired, in either case the cost to maintain the hydrants falls on KIU.

- Q. PLEASE SUMMARIZE AND RESPOND TO THE SJFD WITNESSES'S TESTIMONY REGARDING THE COSTS UNDERLYING THE HYDRANT FEE.
- A. The SJFD witnesses assert that KIU's estimated cost underlying the hydrant fee is overstated due to an overestimation of KIU labor hours per hydrant. Specifically, the SJFD witnesses challenge the amount of time it takes to trim and weed around a hydrant, assert that much of the hydrant landscaping maintenance is performed by non-

KIU employees, and state that training and testing performed by the SJFD does not result in increased costs for KIU.

The time considered to trim hydrants is based on an average of time spent. While some may take 30 minutes, others may take greater than an hour depending on the distance and amount of growth. Due to the high level of irrigation usage and climate of Kiawah Island, trimming must be performed often to keep the landscaping around the hydrants properly maintained.

There are some areas where either the property owner or KICA trim around hydrants, typically when the hydrants are located on a right of way or utility easement. Many of our owners have large investments in landscaping around their homes, and in most cases carry them into the utility easements. The KICA landscape department maintains the rights of way on the Parkway and also some other areas where they have preferred to do the trimming instead of KIU staff. KIU staff are not landscape specialists, and we have found it beneficial to work closely with others to ensure we are not damaging plants that are costly or rare. However, ultimately the maintenance performed by others represents a very small percentage of the hydrants as most are typically cleared by KIU staff.

Contrary to Chief Gilcrease's assertions, SJFD's flushing activities frequently give rise to requests for follow-up service from our residents. Hydrant flushing disturbs sediment in the pipes causing discoloration of water, especially if it is not done thoroughly. When we get a call from a homeowner telling us they have dirty water coming into their home after SJFD testing has occurred, we take immediate remedial

1		action. The procedure to clear the line is not just to go to the individual's home but to
2		start at the beginning of the street, clearing the line systematically until the entire street
3		is clear. This process takes time and can't be done haphazardly. I've attached records
4		of customer calls and responses related to hydrant flushing and related correspondence
5		with the SJFD as Exhibit BD-R1. The hydrant fee helps recover the cost of maintaining
6		the hydrants, but also responding to customer complaints following use of the hydrants
7		by the SJFD.
8	Q.	DID THE SOUTH CAROLINA OFFICE OF REGULATORY STAFF ("ORS")
9		REVIEW THE HYDRANT FEE?
10	A.	Yes, the ORS stated in the Direct Testimony of Matthew P. Schellinger, II:
11		ORS reviewed the cost justification provided by Company witness
12		Dennis in 1 Exhibit BD-10. It is ORS's position that the cost justification
13		provided by KIU to support a decrease in the hydrant maintenance fee
14		is an accurate representation of the annual costs to maintain the fire
15		hydrants on Kiawah Island.
16	Q.	PLEASE RESPOND TO THE SJFD WITNESSES'S RECOMMENDATION TO
17		RECOVER THE COSTS OF HYDRANT MAINTENANCE THROUGH BASE
18		RATES RATHER THAN A HYDRANT FEE.
19	A.	As explained in my direct testimony, charging hydrant fees is a common utility practice
20		that has been accepted by the Commission for KIU over 30 years. The practices of the
21		City of Charleston are irrelevant to the current case. The hydrant fee recovers costs

- 1 incurred by KIU to maintain fire hydrants ready for use for testing or emergency
- 2 purposes by the SJFD.
- 3 Q. PLEASE SUMMARIZE AND RESPOND TO THE SJFD WITNESSES'S
- 4 ASSERTION THAT CHARGING THE HYDRANT FEE TO SJFD IS UNFAIR
- 5 TO RESIDENTS OF WADMALAW ISLAND.
- 6 A. KIU currently charges the fee to the SJFD based on the number of hydrants serviced.
- 7 KIU has no influence on how that fee is recovered by the SJFD from its residents,
- 8 whether through general taxes or specific fees. The recovery of the hydrant fee by the
- 9 SJFD is outside the scope of KIU's rate case.
- 10 Q. DOES THIS CONCLUDE YOUR TESTIMONY?
- 11 A. Yes, it does.

### **EXHIBIT BD-R1**

From: Becky Dennis

Sent: Tuesday, February 27, 2018 7:04 AM

To: Jackie Stanley
Cc: Ryan Kunitzer
Subject: Assistance please

#### Good morning Jackie

I wanted to ask for your help with reminding the SJFD crews that KIU needs to be notified PRIOR to them going out and training. We absolutely do not have an issue with the training that is done but simply ask for advance notice of the time and areas they will be working. Additionally we ask that the scheduled training occurs from our tanks out. This allows the water flow to be carried systematically which minimizes the disturbances within the system

This is important for many reasons — especially to help maintain the quality of the water provided to our customers. Yesterday our staff found them training in Ocean Park but there had been no notification. Thanks in advance for any help you can provide.

Kindest regards,

#### Becky J. Dennis

Director of Operations | Kiawah Island Utility, Inc A SouthWest Water Company 31 Sora Rail Road | Kiawah Island, SC 29455 Telephone 843.768.0641 | Cell 843.296.1432

bdennis@swwc.com Visit us at www.KiawahIslandUtility.com and www.SWWC.com

This electronic transmission contains information that may be confidential or legally privileged. The information is intended for the use of the individual or entity named above. Any unauthorized review, use, disclosure, distribution, downloading or copying of this communication is strictly prohibited. If you are not the intended recipient and have received this communication in error, please immediately contact the sender, delete the e-mail, and destroy all copies of the original message.

From:

Gavin Gilcrease <g.gilcrease@stjfd.org>

Sent:

Wednesday, April 04, 2018 12:07 PM

To:

colleen@stjohnswaterinc.com; Becky Dennis; twest@siuc.org

Subject:

Fw: Hydrant testing

Hydrant testing today.

Thank you

Gavin Gilcrease
Assistant Fire Chief
St Johns Fire District
PO Box 56, Johns Island, SC 29457
0 843-559-9194 C 843-566-3788 F 843 737-0058

From: Robert Whaley

Sent: Wednesday, April 4, 2018 11:24

To: Gavin Gilcrease

Subject: Fwd: Hydrant testing

Today's hydrants testing zones. Also see Capt Jenkins email below.

Station 7 - zone 1. Station 2 - zone 3 Station 4- zone 1&2

#### Get Outlook for iOS

From: Kevin Jenkins

Sent: Wednesday, April 4, 2018 11:21:02 AM

To: Robert Whaley Subject: Hydrant testing

I spoke with Becky Dennis from Kiawah Island Water. She said that we do not have to wait for Station 4 to complete their hydrants. They just ask that we start out from the pumps. The pump on this end is located on Blue Heron Dr. I informed her that we would start at 1300 and work from Blue Heron towards the mansion.

Capt. Kevin D Jenkins

From:

Gavin Gilcrease < g.gilcrease @stjfd.org>

Sent:

Thursday, April 05, 2018 8:45 AM

To:

colleen Ostjohnswaterinc.com; Becky Dennis; twest Osiuc.org

**Subject:** 

Fw: Hydrant zone for 4-5-18

Hydrant testing for 4/5/18. Have a great day

Gavin Gilcrease
Assistant Fire Chief
St Johns Fire District
PO Box 56, Johns Island, SC 29457
Q 843-559-9194 C 843-566-3788 F 843 737-0058

From: Chad Pate

Sent: Thursday, April 5, 2018 08:41
To: Jackie Stanley; Gavin Gilcrease
Subject: Hydrant zone for 4-5-18
Station 7 will be in Zone 1.
Station 4 will be in Zone 1.
Station 6 will be in Zone 4.
Station 2 will be in Zone 1.

#### Chief Chad Pate

St. Johns Fire District
Battalion Chief
PO Box 56
Cell (843) 725-8907
BC Office (843) 203-3819
Head Quarters (843) 559-9194
Fax (843) 737-0058
Email C.Pate@stjfd.org

				W,O, Nut	170	41
		17		-	27/2	700
Priority DEr	nergency	Today   Rou	ine Deferred	Phone	845	(0)
1 T		731				SJX
ed !	DC.	ykd				
		☐ Preventat	ive 'Scomple			
		☐ (nstall			lepair .	Other
Time		Code		-		
250	5	145	n h	40	War	1+
wa	21	ert	hat	7	OKS	
a.						
Seci	21=	# 20	424	189	8	
y THEFE	AND	FULSTAGED	THE H	DRANT	ACROSS	
pm 35	1. I	TOOK F	WHILE P	OU THE	Russ 7	0
rns.) Flu	set For	10 mines				
	L	ATEL LOSS	- 5000	GALS		
	Carrie					
					435.7	
		Materials Used				
Qty. Unit P	r. T	otal Desc	iption	Size Q1	y. Unit Pr.	Total
						-
						-
						1
			1	- 1		1
1 1	4					
-	-					
		TOTAL	IATERIAL			
abor		TOTAL	ATERIAL			
abor UnCt	Hrs	TOTAL M	DATERIAL			
		Total	IATERIAL  8. Amt / Work On	ler		
	Hrs ,5°O	Total	& Amt / Work Ore	ler		
		Total Total Hre	8. Amt / Work Ore	ler		
		Total Total Hrs Labor Co	8. Amt / Work Ore	ler		
		Total Total Hrs Labor Co	& Amt / Work Onst st Materials	ler		
		Total Total Hrs Labor Co Inventory Construct Other	& Amt / Work Onst st Materials			
	Time  2 Se  W  Se  Time  2 Se  Time  2 Se  Time  3 Si  Time  4 Thata	Priority   Emergency  Priority   Emergency	Preventation Install  Time Code  2 Se Siusia  Serial # 29  4 There And Fusited  And 359. It Took A  Thusat For 10 mines.  Waterials Used	Priority   Emergency   Today   Routine   Deferred    Color   Complete   Complete   Complete	WORK ORDER  Priority   Emergency   Today   Routine   Deferred   Phone      Classification   Classification	Priority   Emergency   Today   Routine   Deferred   Phone   SUB

			9								
☐ Customer Re					WORK (	ORDER		W.	O. Numbe	· 170	76
Date '4-10	18	Priority		merger			ie 🖺 Def	erred Ph	one 82	8-713	3-614
Nama Maria	ter 5	Elyn	N)		J						
ocation HILE		ignit		Ne	ND	7					
Assigned To	1 19	LOTHE		1.10				Classi	ication		
Date Assigned		0				☐ Preventativ	• □ Co □ Ca	mplaint	☐ Cust		] Other
Date Due		Tin			10	Code		Dita:			7000
		Lim	ne						<u> </u>		
Work Requested	13	ru	00		wat	er Co	mp	OFF	<u>k</u>		
Nicosi	1 10	NAME OF THE OWNER.	100		010	2			(ESS)		
Neigh	_	lare				0.					
		all	111	nce	Flus	shod					
Work Performed	N 19						•				11112
TOR Fellulled											
and Campl	asint										***
	gerb	LATERIPA	-								
HIGH NI	1- 1-1	enn	1		7/14	-564	-20	500		-	
11.80 10	TONCE	ROVOT			107	- <u>JU/</u> T	_0_	, OG			
Musher	lydran	F	TK	ate	1/1	122	051	000	meul	0	
HOSIGH 9	Autan		V -	- 0141		704 (	170		1	-01	
	<u> </u>								<del>U</del>		
					Materi	nis Used					To a to tall
Description	Size	Qty.	Unit f	er.	Total	Descrip	tion	Size	Qty.	Unit Pr.	Total
		-		_					-		
		+		+		-		-	-		
		+				-			-		
		-		$\dashv$					-		
		+ +				TOTAL MAT	TERIAL			l	
	L	bor				<del>                                     </del>				П	Т
Date	Labor Source		UnCt	Hra	Total						
						Total Hrs & A	Amt / Work	Order			
						Labor Cost					
						Inventory Ma					
	10.00				-	Construction	n Materiais		-		
					-	Other			+		
					F	III mamaa saas			1		
9						TOTAL WO	HK OHDE	H COST			

	omer Request							W.O. 1	lumber	173	/I Q	
	pany Request				WORK					P 1 O	40	-
Date 4~(	3-18	P	Priority 🗆 En	nergeno	y Tod	lay 🔲 Routin	e Deferre	d Phone				$\dashv$
	211.		/		20.			de me n				-
Location	34 (	011	fer (	OUY	100			Classificat	lan			-
Assigned To		MA ARTINI				☐ Preventative		laint [	.c.i ] Custi ] Repa			
Data Assigned	<u> </u>					☐ Install	☐ Capita		Other	$\perp$		
Date Due			Time			Code						
Work Reques	ted	BY	MUY	1	<u> </u>	er C	cople	int				
		-										
Mark Carless												
Work Perions	180	-11021	120	1	10/100	uts						
		-1031	ac.	براي	CIVO	VCII						
		1	10/1	000	1	) 2(	1/ 1/ /	79m	ري.	0		
2.1			MA	ere	/\C	12	1070	<u> </u>	24	<u> </u>		
			1000			-				A A A A A A A A A A A A A A A A A A A		
								- was a street of the street o				
		- V	1724		Materi	als Used	COLUMN TO THE PARTY OF THE PART					
Descrip	tion	Size C	ky. Unit P	r.	Total	Descrip	tion	Size	Qty.	Unit Pr.	Tol	tal
				$\perp$								
				_								
			-	-							-	
-		_	_	_							-	
				-		TOTAL MA	TERIAL	1		<u> </u>	<del> </del>	
$\geq$	1	labar				101VE MW	S tol HPUs			TT	<del></del>	
Date	Labor	Source	UnCt	Hrs	Total	-					-	
1	Ken		- Unot		1000	Total Hra &	Amt / Wark O:	der			-	
413	1001	7,				Labor Cost						
7						Inventory M						
						Construction						
						Other						
						TOTAL W	ORK ORDER	COST				
	<u> </u>						A PROSNERANCE ACTION		L			
Completed	Ву			Re	wiewed By				D	ate		

From: Gavin Gilcrease <g.gilcrease@stjfd.org>

Sent: Monday, May 07, 2018 3:30 PM

To: Becky Dennis

Subject: Re: Hydrant zone for 4-5-18

I sure will Becky. I wasn't aware that anyone was testing today on KI either. I will pass on your concern.

Gavin Gilcrease
Assistant Fire Chief
St Johns Fire District
PO Box 56, Johns Island, SC 29457
D 843-559-9194 C 843-566-3788 F 843 737-0058

From: Becky Dennis <>

Sent: Monday, May 7, 2018 3:25:47 PM To: Gavin Gilcrease; Jackie Stanley Subject: RE: Hydrant zone for 4-5-18

It is my understanding that the fire department has been out again today testing hydrants without prior notification to KIU. This happens all too frequently where I am notified after the fact. Would it be possible to please reiterate to your staff the importance of letting us know prior to going into the system.

Thanks in advance for your assistance.

Kind regards,

#### **Becky J. Dennis**

Director of Operations | Kiawah Island Utility, Inc.

A SouthWest Water Company

31 Sora Rail Road | Kiawah Island, SC 29455

Telephone 843.768.0641 | Cell 843.296.1432

Visit us at and

This electronic transmission contains information that may be confidential or legally privileged. The information is intended for the use of the individual or entity named above. Any unauthorized review, use, disclosure, distribution, downloading or copying of this communication is strictly prohibited. If you are not the intended recipient and have received this communication in error, please immediately contact the sender, delete the e-mail, and destroy all copies of the original message.

From: Gavin Gilcrease

Sent: Thursday, April 05, 2018 8:45 AM To: Becky Dennis <>; twest@sluc.org Subject: Fw: Hydrant zone for 4-5-18 Hydrant testing for 4/5/18.

Have a great day
Gavin Gilcrease
Assistant Fire Chief
St Johns Fire District

PO Box 56, Johns Island, SC 29457

O 843-559-9194 C 843-566-3788 F 843 737-0058

From: Chad Pate

Sent: Thursday, April 5, 2018 08:41

From:

Gavin Gilcrease < g.gilcrease @stjfd.org>

Sent:

Friday, May 11, 2018 9:56 AM

To:

**Becky Dennis** 

Subject:

Hydrant Project

Station 4 will be flow testing in Zone 1 on KI today.

Gavin Gilcrease Assistant Fire Chief St Johns Fire District PO Box 56, Johns Island, SC 29457 O 843-559-9194 C 843-566-3788 F 843 737-0058

From: Becky Dennis

Sent: Thursday, July 12, 2018 3:52 PM

To: Jackie Stanley

Subject: RE: Hydrant maintenance needs

There are no picture attached but will look at the addresses to see what the problem is.

Are they just doing locates or still out testing - If so we have not been getting notifications

Additionally, I never received the list I requested from you last month. I am trying to update my numbers to match those of the Fire Department. Do you know when it will be available?

Thanks Jackie

#### **Becky J. Dennis**

Director of Operations | Kiawah Island Utility, Inc. A SouthWest Water Company 31 Sora Rail Road | Kiawah Island, SC 29455 Telephone 843.768.0641 | Cell 843.296.1432

bdennis@swwc.com | Visit us at www.KiawahIslandUtility.com and www.SWWC.com

This electronic transmission contains information that may be confidential or legally privileged. The information is intended for the use of the individual or entity named above. Any unauthorized review, use, disclosure, distribution, downloading or copying of this communication is strictly prohibited. If you are not the intended recipient and have received this communication in error, please immediately contact the sender, delete the e-mail, and destroy all copies of the original message

From: Jackie Stanley [mailto:j.stanley@stjfd.org]

Sent: Thursday, July 12, 2018 3:07 PM
To: Becky Dennis <br/>
Subject: FW: Hydrant maintenance needs

#### Becky,

I received these pictures and addresses from station six. I need you to please take look at the location and take care of any problems. If you have any question feel free to call me.

**Chief Stanley** 

From: Kevin Jenkins

Sent: Thursday, July 12, 2018 8:35 AM

To: Jackie Stanley

Subject: Hydrant maintenance needs Addresses are attached to the pics

Capt. Kevin D Jenkins

From: Kevin Jenkins

Sent: Wednesday, April 18, 13:31 Subject: Hydrant maintenance needs

From:

Gavin Gilcrease <g.glicrease@stjid.org>

Sent:

Monday, October 08, 2018 9:39 AM

To: Subject: colleen@stjohnswaterinc.com; Becky Dennis; twest@siuc.org

oubjeet.

Fall Hydrant Project

#### **Good Morning,**

We will begin our hydrant project today and run through completion. As I did during the spring, and hopefully a bit more systematically, I will be notifying the group of operational zones.

#### 10/08/18

Johns Island – Zone 1 Seabrook – N/A Klawah Island – N/A

Thank you and have a great week! Gavin

#### Gavin Gilcrease Assistant Fire Chief | St Johns Fire District PO Box 56 Johns Island, SC 29457 O 843.559.9194 | C 843.566.3788 | F 843.737.0058



	-	-					1			-	
☐ Customer Request ☐ Company Request				WORK (	ORDER		W.O. N	umber		177	737
Date 10 - 15 - 18	Priority	y 🗆 Er	mergen	cy 🗆 Toc	lay 🔲 Routine	Deferred	Phone	513	3-52	10-	8500
Name Laura I	)eu	жe ч									
Location 345 1 ow	Da	x.	12	(N)	2	A SHIPPE WHEN					
Assigned To				0	☐ Preventative	Complair	ilessification	on Custo	orlini		
Date Assigned					☐ Install	☐ Capital		Repa			Other
Date Due	Tir	ne			Code						
Work Requested	10-	ter	۲	ĭS_	yello	u.					
- 11 - \ (1.16)	247	0.			()						
- New Constr		August 100 march	7		VETTI-		- 11 m				. ע
- JUST ST	Hot!		tod	- 1	TUYN	s on 4	ellow	40	Jeak	uf	o a litt
Wark Performed	1104			12.1	-> C	old W	10r	75	1 A LOW	7	
					•						
Floshed Hychant	At	3	46	Low	CAKS bib on	8 100 50	X6	50	300	C	lear
Mex with LAURA	Den	ودح	ope	· hose	bib on	has=	Flool	est!	Secu	ice	line
yellow to Clene	140015	red	Mes	Dew	and the second s		side	Fi	حدون	Un	ul clos
						I to make	10		Tox	20	1/
						WATER	L Kos	S	5,2	00 6	90/64
	-			Maleri	als Usad	LVAtes	L Koo	\$	5,2	<u>00</u> _	90/64
Description Size	Qiy.	Unit P	ir.	Materi Total	als Used Descripti	V		S Day.	5,2		galle is
Description Stza	Qly.	Unit P	ir.			V					
Description Size	Qiy.	Unit P	r.			V					
Description Siza	Qiy.	Unit P	Pr.			V					
Description Siza	Oly.	Unit P	ir.			V					
Description Siza	Ohy.	Unit P	F.			V					
Description Stza	Oly.	Unit P	Pr.		Descripti	on Si					
		Unit P	Pr			on Si					
Lab					Descripti	on Si					
		Unit P	Hra	Total	TOTAL MAT	on Si	28				
Lab				Total	TOTAL MAT	on Si	28				
Lab				Total	TOTAL MAT	erial	28				
Lab				Total	TOTAL MAT  Total Hrs & A  Labor Cost Inventory Ma  Construction	erials	28				
Lab				Total	TOTAL MAT  Total Hrs & A Labor Cost Inventory Ma Construction Other	erials  Materials	28				
Lab	or			Total	TOTAL MAT  Total Hrs & A Labor Cost Inventory Ma Construction Other	erials	28				

From: Becky Dennis

Sent: Friday, October 12, 2018 4:39 PM

To: Chief Colleen Walz; Jackie Stanley; 'Ryan Kunitzer'; 'Gavin Gilcrease'

Subject: Hydrants out of service

You may already have been informed that your teams broke the stems on two hydrants this afternoon. The fire hydrant at Red Bay Road and the one at the Strawmarket are both out of service until we can make repairs. Our crews have isolated both at the watch valves and we are in the process of bagging them out of service.

Please make arrangements for these hydrants to remain out of service over the weekend. I will update you as soon as we return them to service.

Kindest regards,

#### **Becky J. Dennis**

Director of Operations | Kiawah Island Utility, Inc. A SouthWest Water Company 31 Sora Rail Road | Kiawah Island, SC 29455 Telephone 843.768.0641 | Cell 843.296.1432

bdennis@swwc.com | Visit us at www.KiawahIslandUtility.com and www.SWWC.com

This electronic transmission contains information that may be confidential or legally privileged. The information is intended for the use of the individual or entity named above. Any unauthorized review, use, disclosure, distribution, downloading or copying of this communication is strictly prohibited. If you are not the intended recipient and have received this communication in error, please immediately contact the sender, detelle the e-mail, and destroy all copies of the original message

From: Sent:

Gavin Gilcrease <g.gilcrease@stjfd.org> Tuesday, October 16, 2018 11:03 AM

To:

Colleen Schild; Becky Dennis; twest@siuc.org

Subject:

**Hydrant Testing** 

#### Kiawah Is Testing in Zones 1 and 2

# Gavin Gilcrease Assistant Fire Chief|St Johns Fire District PO Box 56 Johns Island, SC 29457 O 843.559.9194|C 843.566.3788|F 843.737.0058



From:

Gavin Gilcrease < g.gilcrease@stjfd.org>

Sent:

Wednesday, October 17, 2018 10:17 AM

To:

Becky Dennis; Colleen Schild; twest@siuc.org

Subject:

**Hydrant Testing** 

Klawah Is testing in Zone 2 today

Get Outlook for iOS

				0031			T			
☐ Customer Request ☐ Company Request				CUAL	G DRDEA		W.C	). Numbe	17	840
Date 10 - (7 - (8	>	Priority [	Emerger	icy 🗆 Ted	lay 🔲 Routin	ıe 🔲 Defer	red Pho	€ 842	7518-6	1580
Name Tell -	- V	illa x	la:n.	tenan	CL.			-		
Location 4589	The same of the sa	avuo	-	-				ľ	eiCle+	2
Assigned To							Classific	cation		
Date Assigned		,			☐ Preventativ ☐ Install	e □ Corr □ Cap	•	Cust		Other
Date Due		Time		1	Code	-		T	III	
Work Requested		Bo	אלאע	5 W	ater (	'ama'	aint			
						Jan 14	-	30	98182	8
Work Performed J 10 MINS OWE 1941	FACA PACA MINA	D TWI TO IN 45	73-	DRANTS WAREA 4601	IN 77. LOSS FOIL AN	TOTA	- w	ATRIL		SHD -nows
<b></b>				Materi	als Used		ALTERNATION OF THE PARTY OF THE		_	
Description	Size	Oty. Uni	Pr.	Total	Descrip	lion	Size	Qty.	Unit Pr.	Total
			-							
					TOTAL MA	TERIAL				<u> </u>
	Labo	-	1	1						
	or Source	UnC		Total						-
10-1748 KEN	Far .		751	4		Amt / Work 0	rder	1	1	
<del></del>			+	-	Labor Cost	-tedate		+		_
			+	-	Inventory M			-		
			+	-	Other	NEWNESS		1		
			+	+				+		
					TOTAL WO	PRK ORDER	COST			
Completed By	111/1	IN	В	eviewed By				D	ate 10-	17118

From: Gavin Gilcrease <g.gilcrease@stjfd.org>
Sent: Thursday, October 18, 2018 11:05 AM

To: Colleen Schild; Becky Dennis; twest@siuc.org

Subject: Hydrant Testing

Johns Island testing in Zone 1
Kiawah Island Testing in Zone 1 and 4
Seabrook Island testing in Zone 3 and 4

#### Thank you

Gavin Glicrease
Assistant Fire Chief|St Johns Fire District
PO Box 56 Johns Island, SC 29457
O 843.559.9194|C 843.566.3788|F 843.737.0058



From:

**Becky Dennis** 

Sent:

Thursday, October 18, 2018 1:33 PM

To:

Chief Colleen Walz; Jackie Stanley; 'Gavin Gilcrease'; 'Ryan Kunitzer'

Subject:

Hydrant at 56 Salt Cedar

Your crew just called and stated that they snapped the stem on another hydrant. I am not certain if they are operating them in an incorrect manner or what is occurring but this is the third hydrant within the week. This hydrant will be out of service until we can make the proper repairs. Please acknowledge receipt of this email.

#### Kindest regards

#### **Becky J. Dennis**

Director of Operations | Kiawah Island Utility, Inc. A SouthWest Water Company 31 Sora Rail Road | Kiawah Island, SC 29455 Telephone 843.768.0641 | Cell 843.296.1432

bdennis@swwc.com | Visit us at www.KlawahIslandUtility.com and www.SWWC.com

This electronic transmission contains information that may be confidential or legally privileged. The information is intended for the use of the individual or entity named above. Any unauthorized review, use, disclosure, distribution, downloading or copying of this communication is strictly prohibited. If you are not the intended recipient and have received this communication in error, please immediately contact the sender, delete the e-mail, and destroy all copies of the original message.

From: Gavin Gilcrease <g.glicrease@stjfd.org>
Sent: Thursday, October 18, 2018 1:37 PM

To: Becky Dennis; Colleen Walz; Jackie Stanley; Ryan Kunitzer

Subject: RE: Hydrant at 56 Salt Cedar

#### Thank you

Gavin Gilcrease Assistant Fire Chief|St Johns Fire District PO Box 56 Johns Island, SC 29457 O 843.559.9194|C 843.566.3788|F 843.737.0058



From: Becky Dennis <a href="mailto:becky-bennis@swwc.com">bent: Thursday, October 18, 2018 1:33 PM</a>

To: Colleen Walz <c.walz@stjfd.org>; Jackie Stanley <j.stanley@stjfd.org>; Gavin Gilcrease <g.gilcrease@stjfd.org>; Ryan

Kunitzer <r.kunitzer@stjfd.org> Subject: Hydrant at 56 Salt Cedar

Your crew just called and stated that they snapped the stem on another hydrant. I am not certain if they are operating them in an incorrect manner or what is occurring but this is the third hydrant within the week. This hydrant will be out of service until we can make the proper repairs. Please acknowledge receipt of this email.

#### Kindest regards

#### **Becky J. Dennis**

Director of Operations | Klawah Island Utility, Inc.

A SouthWest Water Company

31 Sora Rail Road | Kiawah Island, SC 29455

Telephone 843.768.0641 | Cell 843.296.1432

bdennis@swwc.com | Visit us at www.KiawahIslandUtility.com and www.SWWC.com

This electronic transmission contains information that may be confidential or legally privileged. The information is intended for the use of the included or entity named above. Any unauthorized review, use disclosure, distribution, downloading or copying of this communication is strictly prohibited. If you are not the intended recipient and have received this communication in error, please immediately contact the sender, delete the e-mail, and destroy all copies of the original message.

From:

Gavin Gilcrease < g.gilcrease @ stjfd.org>

Sent:

Friday, October 19, 2018 12:02 PM

To:

Colleen Schild; Becky Dennis; twest@siuc.org

Subject:

Re: Hydrant Testing

John's Island Zone 2&3 SBI Zone 4 KI Zone 4

#### Get Outlook for iOS

From: Gavin Gilcrease

Sent: Thursday, October 18, 2018 11:05:00 AM

To: Colleen Schild; twest@siuc.org

Subject: Hydrant Testing
Johns Island testing in Zone 1

Kiawah Island Testing in Zone 1 and 4 Seabrook Island testing in Zone 3 and 4

Seabrook Island testing in Zone 3 and 4
Thank you
Gavin Gilcrease
Assistant Fire Chief | St Johns Fire District
PO Box 56 Johns Island, SC 29457
O 843.559.9194 | C 843.566.3788 | F 843.737.0058

From: Sent: Gavin Gilcrease <g.gilcrease@stjfd.org> Monday, October 22, 2018 10:59 AM

To:

Colleen Schild; Becky Dennis; twest@siuc.org

**Subject:** 

RE: Hydrant Testing

Kiawah Island Late addition
Testing Zone 2 as well
Thank you
Gavin Gilcrease
Assistant Fire Chief|St Johns Fire District
PO Box 56 Johns Island, SC 29457
O 843.559.9194| C 843.566.3788| F 843.737.0058

From: Gavin Gilcrease

Sent: Monday, October 22, 2018 8:47 AM

To: Colleen Schild twest@siuc.org
Subject: RE: Hydrant Testing

10/22/18

Johns Island testing in Zone 2 & 3
Seabrook Island Testing in Zone 1&4
Kiawah Island Testing in Zone 1 & 4

**Gavin Gilcrease** 

Assistant Fire Chief | St Johns Fire District

PO Box 56 Johns Island, SC 29457

O 843.559.9194 | C 843.566.3788 | F 843.737.0058

From: Gavin Gilcrease

Sent: Friday, October 19, 2018 12:02 PM

To: Colleen Schild < colleen@stjohnswaterinc.com >; bdennis@swwc.com; twest@siuc.org

Subject: Re: Hydrant Testing John's Island Zone 2&3

SBI Zone 4 KI Zone 4

**Get Outlook for iOS** 

From: Gavin Gilcrease

Sent: Thursday, October 18, 2018 11:05:00 AM

To: Colleen Schild; bdennis@swwc.com; twest@siuc.org

Subject: Hydrant Testing
Johns Island testing in Zone 1
Kiawah Island Testing in Zone 1 and 4
Seabrook Island testing in Zone 3 and 4

Thank you
Gavin Gilcrease

Assistant Fire Chief | St Johns Fire District

PO Box 56 Johns Island, SC 29457

O 843.559.9194 | C 843.566.3788 | F 843.737.0058

From:

**Becky Dennis** 

Sent:

Monday, October 22, 2018 11:34 AM

To:

'Gavin Gilcrease'; Colleen Schild; twest@siuc.org

Subject:

**RE: Hydrant Testing** 

Gavin, I respectfully ask that they please flow the hydrants being tested until the lines are clear to minimize that additional call outs we have for discolored water once they are done. I would rather have more water used on the front end of the testing than increased customer complaints.

Thanks so much.

#### **Becky J. Dennis**

Director of Operations | Kiawah Island Utility, Inc.

A SouthWest Water Company

31 Sora Rail Road | Kiawah Island, SC 29455

Telephone 843.768.0641 | Cell 843.296.1432

bdennis@swwc.com | Visit us at www.KlawahislandUtility.com and www.SWWC.com

This electronic transmission contains information that may be confidential or legally privileged. The information is intended for the use of the individual or entity named above. Any unauthorized review, use, disclosure, distribution, downloading or ropying of this communication is strictly prohibited. If you are not the intended fecipient and have received this communication in error, please immediately contact the sender, delete the e-mail, and destroy all copies of the original message.

From: Gavin Gilcrease [mailto:g.gilcrease@stjfd.org]

Sent: Monday, October 22, 2018 10:59 AM

To: Colleen Schild <colleen@stjohnswaterinc.com>; Becky Dennis <bdennis@swwc.com>; twest@siuc.org

Subject: RE: Hydrant Testing

Klawah Island Late addition
Testing Zone 2 as well
Thank you
Gavin Gilcrease
Assistant Fire Chief|St Johns Fire District
PO Box 56 Johns Island, SC 29457
O 843.559.9194 | C 843.566.3788 | F 843.737.0058

From: Gavin Glicrease

Sent: Monday, October 22, 2018 8:47 AM

To: Colleen Schild twest@sluc.org

**Subject: RE: Hydrant Testing** 

10/22/18

Johns Island testing in Zone 2 & 3 Seabrook Island Testing in Zone 1&4 Kiawah Island Testing in Zone 1 & 4

**Gavin Gilcrease** 

Assistant Fire Chief | St Johns Fire District

PO Box 56 Johns Island, SC 29457

From:

Gavin Gilcrease <g.gilcrease@stjfd.org>
Monday, October 22, 2018 11:47 AM

Sent: To:

Colleen Schild; Becky Dennis; twest@siuc.org

Cc: Subject: Jackie Stanley
RE: Hydrant Testing

Received. I just emailed the duty battalion chief to relay the concern. I will do so for the next couple of days as well to ensure they are all informed.

Thank you

**Gavin Gilcrease** 

Assistant Fire Chief | St Johns Fire District

PO Box 56 Johns Island, SC 29457

O 843.559.9194 | C 843.566.3788 | F 843.737.0058

From: Colleen Schild

Sent: Monday, October 22, 2018 11:45 AM

To: Becky Dennis; Gavin Gilcrease; twest@siuc.org

Subject: RE: Hydrant Testing

Yes, SJWC too. We received numerous customer complaints on Friday. Please start at the beginning of the streets and

test to the end of the streets until clear.

Thanks,

Colleen Schild

Assistant Manager/Engineer

(843) 514-5570

St. John's Water Company

"This institution is an equal opportunity provider and employer"

From: Becky Dennis < bdennis@swwc.com > Sent: Monday, October 22, 2018 11:34 AM

To: Gavin Gilcrease < g.gilcrease@stjfd.org >; Colleen Schild < colleen@stjohnswaterinc.com >; twest@siuc.org

Subject: RE: Hydrant Testing

Gavin, I respectfully ask that they please flow the hydrants being tested until the lines are clear to minimize that additional call outs we have for discolored water once they are done. I would rather have more water used on the front end of the testing than increased customer complaints.

Thanks so much.

#### **Becky J. Dennis**

Director of Operations | Kiawah Island Utility, Inc.

A SouthWest Water Company

31 Sora Rail Road | Kiawah Island, SC 29455 Telephone 843.768.0641 | Cell 843.296 1432

#### bdennis@swwc.com | Visit us at www.KiawahIslandUtility.com and www.SWWC.com

This electronic transmission contains information that may be confidential or legally privileged. The information is intended for the use of the individual or entity named above. Any unauthorized review use, disclosure, distribution, downloading or copying of this communication is strictly prohibited. If you are not the intended recipient and have received this communication in error, please immediately contact the sender delete the e-mail, and destroy all copies of the original message.

From: Gavin Gilcrease [ mailto:g.gilcrease@stjfd.org ]

Sent: Monday, October 22, 2018 10:59 AM

To: Colleen Schild < colleen@stjohnswaterinc.com >; Becky Dennis < bdennis@swwc.com >; twest@siuc.org

**Subject:** RE: Hydrant Testing Klawah Island Late addition

From:

Gavin Gilcrease <g.gilcrease@stjfd.org>

Sent:

Tuesday, October 23, 2018 8:41 AM

To:

Colleen Schild; Becky Dennis; twest@siuc.org

**Subject:** 

RE: Hydrant Testing

#### 10/23/18

Johns Island - Zone 3

Seabrook Island - Zone 2

Kiawah Island - Zones 1, 2, 3, and 4

Gavin Gilcrease
Assistant Fire Chief | St Johns Fire District
PO Box 56 Johns Island, SC 29457
O 843.559.9194 | C 843.566.3788 | F 843.737.0058

From: Gavin Gilcrease

Sent: Monday, October 22, 2018 8:47 AM

To: Colleen Schild twest@siuc.org
Subject: RE: Hydrant Testing

10/22/18

Johns Island testing in Zone 2 & 3 Seabrook Island Testing in Zone 1&4 Kiawah Island Testing in Zone 1 & 4

Gavin Gilcrease

Assistant Fire Chief | St Johns Fire District

PO Box 56 Johns Island, SC 29457

O 843.559.9194 | C 843.566.3788 | F 843.737.0058

From: Gavin Gilcrease

Sent: Friday, October 19, 2018 12:02 PM

To: Colleen Schild < colleen@stjohnswaterinc.com >; bdennis@swwc.com ; twest@siuc.org

Subject: Re: Hydrant Testing John's Island Zone 2&3 SBI Zone 4

SBI Zone 4 KI Zone 4

**Get Outlook for iOS** 

From: Gavin Gilcrease

Sent: Thursday, October 18, 2018 11:05:00 AM

To: Colleen Schild; bdennis@swwc.com; twest@siuc.org

Subject: Hydrant Testing
Johns Island testing in Zone 1

Kiawah Island Testing in Zone 1 and 4 Seabrook Island testing in Zone 3 and 4

From:

Gavin Gilcrease <g.gilcrease@stjfd.org> Thursday, October 25, 2018 9:59 AM

Sent: To:

Colleen Schild; Becky Dennis; twest@siuc.org

Subject:

**RE: Hydrant Testing** 

10/25/18

Kiawah Island Testing Zone 1 &2

**Gavin Gilcrease** 

Assistant Fire Chief | St Johns Fire District

PO Box 56 Johns Island, SC 29457

O 843.559.9194 | C 843.566.3788 | F 843.737.0058

From: Gavin Gilcrease

Sent: Wednesday, October 24, 2018 1:38 PM

To: 'Colleen Schild'

Subject: RE: Hydrant Testing

10/24/18

Johns Island Testing - Zone 2 Kiawah Island Testing - Zone 3

**Gavin Gilcrease** 

Assistant Fire Chief | St Johns Fire District

PO Box 56 Johns Island, SC 29457

O 843.559.9194 | C 843.566.3788 | F 843.737.0058

From: Gavin Gilcrease

Sent: Tuesday, October 23, 2018 8:41 AM

To: 'Colleen Schild' < colleen@stjohnswaterinc.com >; < bdennis@swwc.com >; < twest@siuc.org >

Subject: RE: Hydrant Testing

10/23/18

Johns Island - Zone 3

Seabrook Island - Zone 2

Kiawah Island - Zones 1, 2, 3, and 4

**Gavin Gilcrease** 

**Assistant Fire Chief|St Johns Fire District** 

PO Box 56 Johns Island, SC 29457

O 843.559.9194 | C 843.566.3788 | F 843.737.0058

From: Gavin Gilcrease

Sent: Monday, October 22, 2018 8:47 AM

To: Colleen Schild < colleen@stjohnswaterinc.com >; bdennis@swwc.com; twest@siuc.org

Subject: RE: Hydrant Testing

10/22/18

Johns Island testing in Zone 2 & 3

	lomer Requ Ipany Requi					COME	Hotel F			W.O. I	Vumbe	17	756
Date	10125	5/18	Priori	y [] E	mergi			_	☐ Deferred	Phone			
Name	1 Kh	knee	w	Re	بها	mal	Pren	 دء					
Location	10	61	ee	2	W	reado	الم	2	.1	Var	_		
Assigned To		Ken				· que	, C	4		Classificat			
Date Assigne	d						☐ Preventativ	81	☐ Compta		Cust		Other
Date Due			Т	ime			Code			H			
Work Reques	0 2	elled	40	n	ja	rt	dut	40	er	rater	ر	in 1	ies
You	els	YA	en	k -	<u></u>			/	0				•
hyd	ran	Tr	tod	de	_	- the	ber	<u>گ</u>	dept	· h	ras	flore	reng
Work Perform	ned P	enso	. Or	0	. 1	0	. 1 %	A	1.16.		10.		0.1
a for	llon	-up			32	uru			ncen	w		cree	as
Tis	SURD /	2) 4	4020	W3	7	PC#2	. FOR	_	5 Min	7			
pu	(	de ) [1	420			F#7			The same of the sa	-			
		Kalo	enfil			DOOL	UD GOV	41	15 MIN				-
						15.00	O GAL	110	HOWA				
	I Go	-	- 2			2 Lance	1 25	_	and the same of the	reen	m	LA DOW	
	7	7.10-	1			A Common	ग्र		10 0				
		- I was				Materia	ls Used						manuscriptur .
Descrip	ption	Size	Oty.	Unit F	Pr.	Total	Descrip	rtler	1 9	ize	Qty.	Unit Pr.	Total
										$\neg$			
							TOTAL MA	TEI	RIAL	W. 50			
		Lat	XOF										
Date 10		sbor Source		UnCt	Hrs								
10-25-K	KKN	R			,75	-	1	Aml	/ Work Orde	r			
							Labor Cost						
					-	-	Inventory M	_					
					-	+	Constructio	n M	aterials				
	-					+	Other	_			-		
							TOTAL WO	DRK	CORDER CO	DST			
Completed	By Le	l. Why	uf		1	Reviewed By					De	no 10-29	-18

Nement Platter Durch Location 575 Oyster Rock Assigned To	Processor Deferred Phone (278-593-C)
Location 575 Oyster Rock	
Location 575 Oyster Rock	e
Assigned To	
	Classification  Classification  Custodial
Date Assigned	☐ Preventative ☐ Complaint ☐ Custodial ☐ Install ☐ Capital ☐ Repeir ☐ Other
Date Due Time	Code
Work Requested Brown W	outer Complaint
. W	,
* Throughout house	
Work Performed Flushed Hydraut 1' C	1522 Rake, Flushed Service Line
Fixe Pepz was in the seen sed	
All Close Clear Classing/	
	RAKE 14min x 850 - 11,900
545 11	8 Mr X 850 - 6 800
591 "	11 6 MIN X 900 = 5,400
	340 Clipter hos = 24, 100 applier
	1/45 AM 10-25-18 min
Description Size Qty. Unit Pr. Total	Description Size Qty. Unit Pr. Total
	TOTAL MATERIAL
	TOTAL MATERIAL
Labor Oste Labor Source UnCt Hrs Total	
3.00	Total Hrs & Amt / Work Order
	Labor Cost
	Inventory Materials
	Construction Materials
	The Contract of the Contract o
	Other
Completed By Miles O. Fig. Reviewed B	Other TOTAL WORK ORDER COST

From:

Gavin Gilcrease <g.gilcrease@stjfd.org>

Sent:

Friday, October 26, 2018 8:33 AM

To:

Colleen Schild; Becky Dennis; twest@siuc.org

Subject:

**RE: Hydrant Testing** 

#### 10/26/18

Johns Island will be testing hydrants in zone 3 today.
Seabrook Island will be testing hydrants in zone 1 today.
Kiawah Island will be testing hydrants in zone 3 and 4 today.
Gavin Gilcrease
Assistant Fire Chief | St Johns Fire District
PO Box 56 Johns Island, SC 29457
O 843.559.9194 | C 843.566.3788 | F 843.737.0058

From: Gavin Gilcrease

Sent: Thursday, October 25, 2018 10:59 AM

To: 'Colleen Schild'

Subject: RE: Hydrant Testing

10/25/18

Seabrook Island testing Zones 1 and 4

**Gavin Gilcrease** 

Assistant Fire Chief | St Johns Fire District

PO Box 56 Johns Island, SC 29457

O 843.559.9194 | C 843.566.3788 | F 843.737.0058

From: Gavin Gilcrease

Sent: Thursday, October 25, 2018 9:59 AM

To: 'Colleen Schild' < colleen@stjohnswaterinc.com >; < bdennis@swwc.com >; < twest@siuc.org >

Subject: RE: Hydrant Testing

10/25/18

Kiawah Island Testing Zone 1 &2

Gavin Gilcrease

Assistant Fire Chief | St Johns Fire District

PO Box 56 Johns Island, SC 29457

O 843.559.9194 | C 843.566.3788 | F 843.737.0058

From: Gavin Gilcrease

Sent: Wednesday, October 24, 2018 1:38 PM

To: 'Colleen Schild' < colleen@stjohnswaterinc.com >; < bdennis@swwc.com >; < twest@siuc.org >

Subject: RE: Hydrant Testing

10/24/18

Johns Island Testing - Zone 2 Kiawah Island Testing - Zone 3

**Gavin Gilcrease** 

Assistant Fire Chief | St Johns Fire District

PO Box 56 Johns Island, SC 29457

O 843.559.9194 | C 843.566.3788 | F 843.737.0058

			- 4	1		PAMI	DIETE		)					
	omer Reque pany Reque					WORK C	50.0		w.c	). Numbe	ef	17	75	7
Date /0-	26 - 18		Priori	ty 🗆 E	merger	cy 🗆 Tod		na 🗌 Del	erred Pho	no 84	3 - 7	68-	928	7
		IN WA	12.D							u; E	a bankley and	-		- Marian
		BUFFERF		DR	vK.									
Assigned To	KEN		J. 1/10	UI-					Classific	cation				
Date Assigner		27-18					☐ Preventativ	ve ⊡Ca ⊡Ca	mplaint	Cus		П	Other	
Date Due	10-	77-18	Т	ime /	0:16		Code	H	J.	-	TT	H	T	
Work Reques	ted Br	ו מנטס	JA:Ni	<u>I</u> L										_
		L WK			76-11	?	and other sections of the section of							
		DATO VOL												
	17:01								***					
Work Perform	ned C	turo	Mo	LU	14020	BACK	TO CH	HICK T	HE CL	ARIT4	105-	יך	teic	
W	ATHER	AND 1	the.	らうへと	E	Sperpar	in Bs	N 170	N FXF	RLIE	rede	2	31200	w
u	1ATRAL	a Wir	EU	EC	nu	ED H	in BA	CH H	€ 547	yb 7	MUST	ブ	ME	
W	ATER	HAD	CCH	PULLO.	-up	EARLIA	a DN	10-27-	18,					
												anc.		
						Materia	ds Used							
Descrip	tion	Size	Qty.	Unit I	Pr.	Total	Descrip	otion	Size	Oty.	Unit	Pr.	To	tal
					-									
		***	-		-					-	<u> </u>			
					-					-				
-			-				-			-				
					-							-		
					$\rightarrow$		TOTAL MA	TERIAL						
		1 -1		<u> </u>			TOTAL	LINE			T		_	
Date	L	Lai ibor Source	A.A.	UnCt	Hrs	Total	<u> </u>	-			+	+	+-	
10-27-18		VE			NA		Total Hrs &	Amt / Work	Order		_		+	
700710	- KO		LED		1/15		Labor Cost			T				
							Inventory M	laterials						
		- Augustus					Constructio	n Materials						
							Other							
							TOTAL W	ORK ORDE	R COST					
Completed	1/	11.1	0.0		1.	winwad Du	1				ata 16			

	ner Request my Request			WORK O	RDER		W.O. Numb	er 17	7859
Pate 10 - 3	31-18	Priority 🗀 En	nergenc	y Toda	y   Routine	☐ Deferred	Phone 84	13-768-	-7496
ame P	Obert	DOIS	SOM	7 2	312				
ocation 51		narsh	7	ne					
ssigned To					Preventative	☐ Complaid	lassification	stodial	
late Assigned					☐ Install	☐ Capital	n □ Cu		] Other
ate Due		Time			Code				
ork Requeste	d ()	mplair	S	OF Y	nunc	Wate	r la	st We	ecc.
	10 11 1	1		7 6	T	11-			
	to MOT	f.r_i_S_1	<b>D</b> (1)	<u>v_(</u>	lear				
		NOV	k	1304	Len T-	estect	1		
/ork Performs	nd .	A. A. Vocasi							
Met u	Ah Mr. De	Ison Si	mple	was	en far	01.0	2.mg/L	g Ave	him
l'or of	Parvite las	Service	Pre	nidens	Expla	ined show	- we a	lo not	Smyle
in Real	Luce only	HL Sic	e-1	, F Re	equested.			~~~	
They	will oull be	role if	the	7 WH	nt 765 t	ed AL	Steeet	2.554	a-1 10-31-16
	- Marie 197					-			
				94.2	de Heard				
Descript	ion Size	Qty. Unit P	.	Total	ls Used Descripti	ion S	ize Oty	Unit Pr.	Total
Dasenhi	JOH GIES	Gray. Cont.	-						
			_						
			_						-
			-		TOTAL MAT	ERIAL			-
	Lab	or					(a-11)		
Date	Labor Source	UnCt	Hrs	Total					
					-	mt / Work Orde	r		
					Labor Cost				
				-	Inventory Ma				
			-	-	Construction	Malerials			
					Other TOTAL WO	RK ORDER C	DST		
			1_	1				Date	
Completed E	3y		B	eviewed By				Date	

From: Gavin Gilcrease <g.gilcrease@stjfd.org>
Sent: Tuesday, February 05, 2019 2:10 PM

To: Becky Dennis
Subject: Hydrant Training

STJFD will be training in KI zone 1 this afternoon.
Gavin Gilcrease
Assistant Fire Chief|St Johns Fire District
PO Box 56 Johns Island, SC 29457
O 843.559.9194| C 843.566.3788| F 843.737.0058

From:

Gavin Gilcrease < g.gilcrease@stjfd.org>

Sent:

Wednesday, February 06, 2019 8:38 AM

To:

**Becky Dennis** 

**Subject:** 

FW: Hydrant Repair

I didnt realize this was sent to me yesterday. Looks like one of the 2.5" caps was cross threaded onto the hydrant.

**Gavin Gilcrease** 

Assistant Fire Chief | St Johns Fire District PO Box 56 Johns Island, SC 29457

O 843.559.9194 | C 843.566.3788 | F 843.737.0058

From: Chad Pate

Sent: Tuesday, February 5, 2019 1:46 PM

To: Gavin Gilcrease

Subject: Fw: Hydrant Repair

I just got this email from S. Ramsey.

#### Chief Chad Pate

#### St. Johns Fire District

#### **Battalion Chief**

PO Box 56

Cell (843) 725-8907

BC Office (843) 203-3819

Head Quarters (843) 559-9194

Fax (843) 737-0058

Email C.Pate@stjfd.org

From: Sean Ramsey

Sent: Tuesday, February 5, 2019 1:07 PM

To: Chad Pate

Cc: Matthew Ebersold; Kyle Cahill

Subject: Hydrant Repair

Chief Pate.

Hydrant located at 4732 Tennis Club Ln has stripped threads on the 2 1/2" outlet on the left side. We are unable to hook up our 2 1/2" ball valve. We placed the cap back on and just used the one side with the 4 1/2" outlet.

Thank you, Sean Ramsey Lieutenant St. Johns Fire District A Shift/ Station 4 (843) 670-7932 s.ramsey@stjfd.org